



TYPE APPROVAL CERTIFICATE
No. MAC225913CS

This is to certify that the product identified below is in compliance with the regulations herewith specified.

<i>Description</i>	Shields for flanged connections
<i>Type</i>	NoSpray Protection System tape & sheet (IM 2002)
<i>Applicant</i>	INNOVATIVE MANUFACTURING INC. 861 DERWENT WAY V3M 5R4 DELTA CANADA
<i>Manufacturer</i>	INNOVATIVE MANUFACTURING INC.
<i>Place of manufacture</i>	861 DERWENT WAY V3M 5R4 DELTA CANADA
<i>Reference standards</i>	Part C, Chapter 1, Section 10 of RINA Rules and SOLAS 74 as amended

Issued in **Genoa** on **September 30, 2013**. This Certificate is valid until **September 29, 2018**

RINA Services S.p.A.
Francesco Sciacca

This certificate consists of this page and 1 enclosure



TYPE APPROVAL CERTIFICATE
No. MAC225913CS
Enclosure - Page 1 of 1
NoSpray Protection System tape & sheet

Reference documents

NoSpray booklet dated July 6, 2004.

Materials and technical characteristics

Aluminium/glass cloth jacketing system with one side coated with a silicon adhesive for installation.
Total thickness 9.5 mil (including 3.3 mil clear film liner).

Field of application

Flanged and screwed connections of fuel oil systems, lubricating oil and other flammable fluids for which the shield is requested as per SOLAS Convention 74 as amended and RINA Rules.

Nominal Pipe Diameter: up to 50 mm for screwed and flanged joints
Maximum pressure: 20 bar
Maximum temperature: 150 °C

Remarks

The installation on board is to be carried out in accordance with the Manufacturer's instructions and to the satisfaction of RINA Surveyor.

The extent of use is limited to spray shielding application on oil pressure pipes located above the floor plates and which have no insulation in way of the joints.

Use is also restricted to readily accessible positions where the integrity of the application may be inspected regularly and new covering will be applied after removal for maintenance purposes.

The application is limited to piping locations permitted by applicable SOLAS/RINA Rules. In any case the use is not permitted for connections located over high temperature surfaces unless the hot surfaces are effectively protected (e.g. by means of metallic shields, drip pans or equivalent protections).

This certificate cancels and replaces the previous one No. MAC319509CS dated 28 July 2009.

Genoa September 30, 2013



RINA Services S.p.A.
Via Corsica, 12 - 16128 Genova
Tel +39 010 53851
Fax +39 010 5351000

